

**City of Jacksonville Water Quality Report
Violations Table**

Chlorine			
Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.			
Violation Type	Violation Begin	Violation End	Violation Explanation
Monitoring, Routine (DBP), Minor	4/1/2011	6/30/2011	Due to the flooding of the Water Plant - We failed to complete all the required tests of our drinking water for the contaminant and period indicated.

Public Notification Rule			
The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).			
Violation Type	Violation Begin	Violation End	Violation Explanation
Public Notice Rule Linked To Violation	7/16/2011	7/20/2011	Due to the flooding of the Water Plant - We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations within the required time frame.

Surface Water Treatment Rule (SWTR)			
The Surface Water Treatment Rule seeks to prevent waterborne diseases caused by viruses, Legionella, and Giardia Lamblia. The rule requires that water systems filter and disinfect water from surface water sources to reduce the occurrence of unsafe levels of these microbes.			
Violation Type	Violation Begin	Violation End	Violation Explanation
Monitoring, RTN/RPT Minor (SWTR-Filter)	6/1/2011	6/30/2011	Due to flooding of the Water Plant - We failed to complete all the required tests of our drinking water for the contaminant and period indicated.

Total Coliform			
Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.			
Violation Type	Violation Begin	Violation End	Violation Explanation
MCL (TCR), Monthly	5/1/2011	5/31/2011	Total coliform bacteria were found in our drinking water during the period indicated in enough samples to violate a standard.
Monitoring (TCR), Routine Minor	6/1/2011	6/30/2011	Due to flooding of the Water Plant - We failed to complete all the required tests of our drinking water for the contaminant and period indicated.